

ADDENDUM No. 1

Date: 11/28/2018

DORMITORY AUTHORITY - STATE OF NEW YORK

**ALFRED STATE COLLEGE
BRADDON HALL & PEET HALL
CURTAIN WALL REPLACEMENT AND ASBESTOS
AND HAZARDOUS MATERIALS ABATEMENT
RE-BID
3409309999 CR 4**

This **ADDENDUM** is hereby included in and made part of the Contract whether or not attached thereto. All requirements of the original Specifications and Drawings shall remain in force except as noted by this **ADDENDUM No. 1**

THE PURPOSE OF THIS ADDENDUM IS TO CHANGE THE FOLLOWING ITEMS:

Item No. 1 – Specification Section 012900 – Payment and Procedures - Schedule of Values referenced in Paragraph 1.1-A, **DELETE** Schedule of Values attachment in its entirety. **ADD** Schedule of Values attachment included here in.

Item No. 2 – Specification Section 084413 – Glazed Aluminum Curtain Walls - **ADD** Paragraph 2.6-D as follows:

- D. Solid Surface Sills.
1. Basis-of-design: Corian surfaces from the DuPont company.
 2. Solid polymer components.
 - a. Cast, nonporous, filled polymer, not coated, laminated or of composite construction with through body colors meeting ANSI Z124.3 or ANSI Z124.6.
 - b. Superficial damage to a depth of 0.010 inch (.25 mm) shall be repairable by sanding and/or polishing.
 3. Thickness: 3/4 inch.
 4. Edge treatment: Eased edge with a 1.5-inch finished apron.
 5. Joint adhesive: Manufacturer's standard one- or two-part adhesive kit to create inconspicuous, nonporous joints.

Attachments: 012900 Payment Procedures Attachment – SCHEDULE OF VALUES

END OF ADDENDUM

THIS PAGE INTENTIONALLY LEFT BLANK

SCHEDULE OF VALUES

Date: _____

Contract No: _____

Project No: 3409309999

Project: Alfred State College - Braddon & Peet Halls - Curtain Wall Replacement

Contractor: _____

CR No: _____

Trade: _____

CSI	DESCRIPTION	UM	QTY	LABOR	MATERIAL	SCHEDULED VALUE
010000	Bonds	LS				\$ -
010000	Insurances	LS				\$ -
010000	Submittals	LS				\$ -
010000	Mobilization	LS				\$ -
010000	Demobilization	LS				\$ -
010000	Final Cleaning	LS				\$ -
010000	Close Out	LS				\$ -
010000	Supervision	LS				\$ -
010000	Scheduling	LS				\$ -
010000	Debris Removal	LS				\$ -
Braddon Hall						
024119	Select Demolition	SF				\$ -
000049	Hazardous Materials - PCBs	LF				\$ -
040120	Maintenance of Unit Masonry	SF				\$ -
084413	Aluminum Curtain Wall	SF				\$ -
085113	Aluminum Windows	SF				\$ -
088000	Glazing	SF				\$ -
092900	Gypsum Board	SF				\$ -
099123	Interior Painting	SF				\$ -
Alternate - Braddon Hall						
024119	Select Demolition	SF				\$ -
000049	Hazardous Materials - PCBs	LF				\$ -
084413	Aluminum Curtain Wall	SF				\$ -
085113	Aluminum Windows	SF				\$ -
088000	Glazing	SF				\$ -
092900	Gypsum Board	SF				\$ -
099123	Interior Painting	SF				\$ -
Peet Hall						
024119	Select Demolition	SF				\$ -
000049	Hazardous Materials - PCBs	LF				\$ -
000049	Asbestos Abatement	LF				\$ -
040120	Maintenance of Unit Masonry	SF				\$ -
084413	Aluminum Curtain Wall	SF				\$ -

