

BINGHAMTON
UNIVERSITY
STATE UNIVERSITY OF NEW YORK

PHYSICAL FACILITIES
PO BOX 6000 BINGHAMTON, NY 13902
(607) 777-3341 - FAX (607) 777-6643

MEMORANDUM

DATE: March 20, 2020

SUBJECT: Addendum # 2
Project #: WO255150
Title: East Gym Fit Court Site Work and Lighting

Bid Opening Date: April 1st at 2:30pm

Please note the following addendum/changes in the bid proposal. All bids received will be in accordance with this addendum. All other specifications, terms and conditions remain the same.

CONTRACTOR TO NOTE RECEIPT OF THIS ADDENDUM NO. 2 ON THE PROPOSAL FORM.

ITEM 1:

Specifications

- A. Section 03300 – Cast In Place Concrete, all concrete for this project shall comply with details on drawings and shall comply with concrete mixture for 4,000 psi concrete strength.

End of addendum