

SUBJECT: RFI #7 – Sound Attenuator Schedule Update

BULLETIN 05

- OWNER Cornell University (CU)
- ARCHITECT Goody Clancy & Associates (GCA)
- CONTRACTOR Whiting-Turner (WT)
- CONSULTANT

PROJECT: Cornell University Balch Hall Renovation

DATE: 9/16/22

TO: The Whiting-Turner Contracting Company
1720 Spillman Drive Suite 180
Bethlehem, PA 18015

ARCHITECT'S PROJ. NO: 07400
CONTRACT DATE:
CONTRACT FOR:

ATTN: Zack Lynn

SUPPLEMENTAL INSTRUCTIONS

(SI)

The work shall be carried out in accordance with the supplemental instructions described herein issued in accordance with the Contract Documents without change in the Contract Sum or Contract Time. Prior to proceeding in accordance with these instructions, indicate your acceptance of these instructions for minor change to the Work as consistent with the Contract Documents and return a copy to the Architect.

PROPOSAL REQUEST

(PR)

Please submit an itemized quotation for the changes in the Contract Sum and/or Contract Time incidental to proposed modifications to the Contract Documents described herein. THIS IS NOT A CHANGE ORDER NOR A DIRECTION TO PROCEED WITH THE WORK DESCRIBED HEREIN.

CONSTRUCTION CHANGE DIRECTIVE

(CCD)

You are hereby directed to make change(s) in the Contract as described herein.

PROPOSED ADJUSTMENTS

1. The proposed basis of adjustments to the Contract Sum is:
 - Lump sum (increase) (decrease) of \$
 - Unit Price of \$_____ per_____
 - Time & materials not to exceed \$
 - Final cost to be determined
2. The Contract Time is proposed to remain unchanged

When signed by the Owner and architect and received by the Contractor, this document becomes effective IMMEDIATELY as a Construction Change Directive (CCD), and the Contractor shall proceed with the changes as described herein. Signature by the Contractor indicates agreement with the proposed adjustments in Contract Sum and Contract Time set forth in this Construction Change Directive.

Origin: RFI 007 requested clarification regarding DS-1 sound attenuator bring called out as a "T" shaped attenuator in the silencer schedule, whereas it shows up graphically as not "T" shaped. It was clarified that the model number in the silencer schedule was incorrect and revised to be an elbow type, similar to DS-2 and DS-3.

DRAWING CHANGES:

M0.03

- Revised duct silencer schedule

Attachments:

Drawing Sheet – M0.03

End of Bulletin 05

Issued by:

Accepted by:

Accepted by:



9/16/22

Architect

Date:

Contractor

Date

Owner

Date

