

SUBJECT: Lighting Clarifications**BULLETIN 07**

OWNER Cornell University (CU)
 ARCHITECT Goody Clancy & Associates (GCA)
 CONTRACTOR Whiting-Turner (WT)
 CONSULTANT

PROJECT: Cornell University Balch Hall Renovation**DATE:** 9/16/22

TO: The Whiting-Turner Contracting Company
 1720 Spillman Drive Suite 180
 Bethlehem, PA 18015

ARCHITECT'S PROJ. NO: 07400
CONTRACT DATE:
CONTRACT FOR:

ATTN: Zack Lynn**SUPPLEMENTAL INSTRUCTIONS** (SI)

The work shall be carried out in accordance with the supplemental instructions described herein issued in accordance with the Contract Documents without change in the Contract Sum or Contract Time. Prior to proceeding in accordance with these instructions, indicate your acceptance of these instructions for minor change to the Work as consistent with the Contract Documents and return a copy to the Architect.

PROPOSAL REQUEST (PR)

Please submit an itemized quotation for the changes in the Contract Sum and/or Contract Time incidental to proposed modifications to the Contract Documents described herein. THIS IS NOT A CHANGE ORDER NOR A DIRECTION TO PROCEED WITH THE WORK DESCRIBED HEREIN.

CONSTRUCTION CHANGE DIRECTIVE (CCD)

You are hereby directed to make change(s) in the Contract as described herein.

PROPOSED ADJUSTMENTS

1. The proposed basis of adjustments to the Contract Sum is:
 - Lump sum (increase) (decrease) of \$
 - Unit Price of \$_____ per_____
 - Time & materials not to exceed \$
 - Final cost to be determined
2. The Contract Time is proposed to remain unchanged

When signed by the Owner and architect and received by the Contractor, this document becomes effective IMMEDIATELY as a Construction Change Directive (CCD), and the Contractor shall proceed with the changes as described herein. Signature by the Contractor indicates agreement with the proposed adjustments in Contract Sum and Contract Time set forth in this Construction Change Directive.

Origin: This Bulletin captures clarifications to the electrical lighting plans based on Bid RFI 3.2.

SPECIFICATION CHANGES:

None

DRAWING CHANGES:

- E4.11A
 - Revised light fixture types per RFI 3.2.
 - RFI Log Item 3.2:
 - All fixture types labeled F1A shall change to fixture type F1B.
 - All fixture types labeled F1D shall change to fixture type F1.
 - Fixture type F1D EM shall be changed to fixture type F1 EM on an Emergency Circuit.
 - All fixture types labeled F2 (single bedroom fixtures) shall change to fixture type F3B.
 - All fixture types labeled F2A (double bedroom fixtures) shall change to fixture type F3.
 - All fixture types labeled F13A shall change to fixture type F13.
 - All fixture types labeled F14 shall change to fixture type F22.
 - All fixture types labeled F16A shall change to fixture type F21.
- E4.12A
 - Revised light fixture types per RFI 3.2.
- E4.12B
 - Revised light fixture types per RFI 3.2.
- E4.12C
 - Revised light fixture types per RFI 3.2.
- E4.13A
 - Revised light fixture types per RFI 3.2.
- E4.13B
 - Revised light fixture types per RFI 3.2.
- E4.13C

- Revised light fixture types per RFI 3.2.
- E4.13D
 - Revised light fixture types per RFI 3.2.
- E4.14A
 - Revised light fixture types per RFI 3.2.
- E4.14B
 - Revised light fixture types per RFI 3.2.
- E4.14C
 - Revised light fixture types per RFI 3.2.
- E4.14D
 - Revised light fixture types per RFI 3.2.
- E4.15A
 - Revised light fixture types per RFI 3.2.
- E4.15B
 - Revised light fixture types per RFI 3.2.
- E4.15C
 - Revised light fixture types per RFI 3.2.
- E4.15D
 - Revised light fixture types per RFI 3.2.
- E4.16B
 - Revised light fixture types per RFI 3.2.
- E4.16D
 - Revised light fixture types per RFI 3.2.

Attachments:

Drawing Sheets:

E4.11A, E4.12A, E4.12B, E4.12C, E4.13A, E4.13B, E4.13C, E4.13D, E4.14A, E4.14B, E4.14C, E4.14D, E4.15A, E4.15B, E4.15C, E4.15D, E4.16B, E4.16D

End of Bulletin 07

Issued by:

Accepted by:

Accepted by:



9/16/22

Architect

Date:

Contractor

Date

Owner

Date

Josh Swasey

