

## ADDENDUM NO. 1

May 21, 2019

This Addendum contains changes to the requirements of the Contract Documents and Specifications. Such changes are to be incorporated into the Construction Documents and shall apply to the work with the same meaning and force as if they had been included in the original document. Wherever this Addendum modifies a portion of a paragraph of the specifications or a portion of any Drawing, the remainder of the Paragraph or Drawing shall remain in force.

NOTE: Provisions of all Contract Documents apply.

---

### INSTRUCTION TO BIDDERS

- Item 1. INSTRUCTIONS TO BIDDERS, INS-1  
3. METHOD OF SUBMISSION, b.

**DELETE** "...not later than 2:00PM on May 29, 2019."

**REPLACE** with "...not later than 2:00 PM on **June 12, 2019**".

- Item 2. Bid Form BF-3, Item 4.a

**DELETE** "Work shall be completed within seventy-five (75) calendar days..."

**REPLACE** with "Work shall be completed within **one hundred sixty-two (162)** calendar days..."

**DELETE** "The currently scheduled contract approval date is June 5, 2019."

**REPLACE** with "The **anticipated** contract approval date is **August 30, 2019**."

### GENERAL REQUIREMENT ITEMS

- Item 3. Section 01 11 00: Part 1.3, Contract Milestones

**DELETE** Item A in its entirety.

**REPLACE** with:

- A. Project end date is currently targeted to be February 7, 2020.

**DRAWINGS**

Item 4. Drawing A-1

**DELETE** in its entirety.

**REPLACE with revised** A-1, attached.

Revisions noted are:

**REVISED Note on 1/A-1 to read - “1/2” Tempered Glass Panels, 4’-0” sections, +/- 8’-10” high X 42’-0” long”, in lieu of 3/4” Tempered....**

**REVISED 2/A-1** to show dimension runs of new Type A light fixtures.

**REVISED Lighting Fixture Schedule** for light fixture model number, and specification of dimmer switch.

Item 5. RFI Questions and Clarifications

See attached RFI Log (Items 1-2)

Attachments: Drawing A-1  
RFI Log (Items 1-2)

**\*\*\*\*END OF ADDENDUM\*\*\*\***

## RFI Form

RFI/ Response Index	Page/ Dwg./Spec./Rep. Number	Section/ Paragraph/Topic	RFI	Design Team Response
1	Drawing A-1 and E-1		The rowed lighting layout shown on drawing A1 is different then shown on E1. Which drawing is correct?	See Addendum 1, Item 4.
2	Drawing A-1		Please confirm the type A light fixture specified on drawing A1 is correct. It seems like it might be the model of what's currently installed and not a new LED version of what's needed.	See Addendum 1, Item 4.