

ADDENDUM NO. 2

February 14, 2018

This Addendum contains changes to the requirements of the Contract Documents and Specifications. Such changes are to be incorporated into the Construction Documents and shall apply to the work with the same meaning and force as if they had been included in the original document. Wherever this Addendum modifies a portion of a paragraph of the specifications or a portion of any Drawing, the remainder of the Paragraph or Drawing shall remain in force.

NOTE: Provisions of all Contract Documents apply.

Item 1. Drawing A-101

DELETE Key Note 3 in its entirety.

REPLACE with

Provide carpet tile over existing terrazzo floor throughout suite and offices.

Item 2. Drawing A-101, Partition Type 1A, Notes:

ADD

2. Provide resilient floor base. Basis of Design: Johnsonite Traditional Vinyl Type TV, height to match existing. Color as selected by Owner.

Item 3. RFI Questions and Clarifications

See attached RFI Log (Items 1-6)

Attachments: RFI Log (Items 1-6)

******END OF ADDENDUM******

RFI Form

RFI/ Response Index	Page/ Dwg./Spec./Rep. Number	Section/ Paragraph/Topic	RFI	Design Team Response
1	Section 096813 Drawing A-101	Keynote 3	<p>a. Spec Section 096813 Tile Carpeting clearly calls out Carpet tile as a finish. Print A-101 calls out in Key Note 3 Legend/Renovation/ Item #3 Broadloom capet with padding. Which is correct?</p> <p>b. The same keynote also says to provide subfloor. If so, What material and thickness?</p> <p>c. What is the subfloor under the existing carpet?</p> <p>d. What is the subfloor being installed under the new carpet tiles?</p>	See Addendum No. 1, Item 1. Spec Section 096813 is correct.
2	Drawing A-101		Does new carpet tile flooring extend under the existing kitchenette that stays?	No, the new carpet tile does not extend beneath the existing kitchenette.
3	Drawing A-101		Is new resilient floor base required? If so, please provide spec.	See Addendum No. 1, Item 2.
4	Drawing A-101		Is there wall base as shown on partition types at top right of print A-101? If so, Vinyl or Rubber?	See Addendum No. 1, Item 2.
5	Drawing A-101		Is there existing floor base to be removed?	There is no existing floor base to be removed.
6	Drawing A-101		Is new ACT ceiling to be included in room S2005A? 4/A-101 seems to show new ACT ceiling in this room. 3/ A-101 does not show us removing the ceiling.	Existing ACT ceiling should remain. Extent of removals is shown in dashed line, bold line where new is to be provided.