

**Campbell Savona Central School District
2017-18 Capital Outlay Project
HUNT 2450-025**

High School SED No.: 57-06-03-04-0-001-021

BID ADDENDUM NO. 2

March 5, 2018

The following Addendum items shall be considered a part of the contract documents prepared by HUNT ENGINEERS, ARCHITECTS & LAND SURVEYORS; P.C., Bid Document date of December 15, 2017.

Revisions to Bid Addendum 1:

ITEM AD 2.1 Bid Addendum 1 Date

AMEND Document Date to read: "February 28, 2018".

ITEM AD 2.2 Refer to Item AD1.3: 08 11 13 – Hollow Metal Doors and Frames

AMEND paragraph 2.3.A.2 as follows: "2. Core: Vertical Steel Stiffeners with polystyrene core."

Revisions to Contract Drawings:

ITEM AD 2.3 Refer to Drawings A2 First Floor – Partial Plan and Door Details

ADD the following notes to the Door Schedule for Doors 1012-3 and 1025-3: "Remove surface apply door seal at head and jambs of frame. Provide adjustable perimeter seals equal to 104NA by National Guard Products, Inc. Delete (3) hinges and provide continuous hinge. Modify existing frame to accommodate installation of new lockset."

ADD the following note to the Door Schedule for Doors 1015-2 and 1021-3: "Modify existing frame to accommodate installation of new lockset."

End of Addendum No. 2