

## **BID ADDENDUM NO. 7**

May 31, 2018

**Elmira City School District**  
**Ernie Davis Academy 2018 Additions & Alterations**  
**HUNT No.: 2012-211**

**SED #07-06-00-01-0-038-026**

The following Addendum items shall be considered a part of the contract documents prepared by HUNT ENGINEERS, ARCHITECTS & LAND SURVEYORS; P.C., Bid Document date of June 29, 2017; issued for bid April 25, 2018.

### **Clarifications issued by this Addendum:**

1. New Panels PP-D108, PP-D113 and PP-D114 shall be fed from Panel L1 in the Boiler Room 100A3P breaker using (3) #2, (1) #2G., 1-1/2" C. per panel.

### **Revisions to Drawings issued by this Addendum:**

#### **ITEM AD5-1 Refer to Drawings T1.2 – T1.10, Technology Plans**

**AMEND** note 5 to read: "Provide installation of ceiling mounted paging speaker and backbox. Speaker and backbox provided by paging system integrator. Modify and extend existing speaker cabling for new speaker locations, where required, and make connection to existing paging system head end. Provide west Penn 25-290, or equivalent, for classroom speakers, and west Penn 25-224 for corridor speakers. Coordinate terminations with paging system integrator."

End of Addendum (7)