

BID ADDENDUM NO. (7)

1/23/26

Hammondsport Central School District

2025 Capital Improvements Project

1925-014

(SED #57-25-01-04-0-002-025 – Main Building)

(SED #57-29-01-04-5-003-008 – Bus Garage)

The following Addendum items shall be considered a part of the contract documents prepared by HUNT ENGINEERS, ARCHITECTS, LAND SURVEYORS & LANDSCAPE ARCHITECT, DPC.
Bid Document date of (10/27/2025).

Clarifications issued by this Addendum:

1. N/A

Project Manual Sections issued by this Addendum:

N/A

Drawings issued by this Addendum:

N/A

Revisions to Project Manual issued by this Addendum:

ITEM AD7-1 Refer to Addendum #6

DELETE ITEM AD6-2 in its entirety.

ITEM AD7-2 Refer to Section 01 10 00 - Summary

AMEND Specification Section 1.9, 12 to read:

“12. Provide the complete work of Specification Section 14 28 16 - Elevator Equipment with the following exceptions:

a. Power and final connection to all electrically operated conveying equipment be provided by the Electrical Contractor.

13. Provide the complete work of Division 31 – Earthwork with the following exceptions:

a. Specification Section 31 23 16.13 – Trenching:

- 1) Interior trenching for utilities shall be provided by Contractor requiring trench, as outlined in previous article.
- 2) Provide exterior trenching for all trades.
- b. Specification Section 31 23 23 – Fill
 - 1) Fill for the interior trenches for utilities shall be provided by Contractor backfilling trench, as outlined in previous article.

14. Division 32 – Exterior Improvements

15. Division 33 – Utilities”

ITEM AD7-3 Refer to Section Refer to Section 01 10 00 - Summary

- ADD** Specification section 1.11, 4., a. to read as: "Specification Section 14 45 00 - Vehicle Service Lift
- 1) Provide final compressed air connections to all Vehicle Service Lift equipment. Refer to A series drawings."

ITEM AD7-4 Refer to Section Refer to Section 01 10 00 - Summary

- ADD** Specification section 1.13, 8., b. to read as: "Section 14 45 00 - Vehicle Service Lift .
- 1.) Power and final connections to all electrically operated conveying equipment to be provided by the Electrical Contractor."

Revisions to Drawings issued by this Addendum:

ITEM AD7-5 Refer to Section Refer to MB-P3.1 – SCHEDULES & SYMBOLS SCHEMATICS

- AMEND** "LAV-1" MFG./MODEL to read as: "AMERICAN STANDARD 0355.012"
- AMEND** "LAV-1" TRIM to read as: SENSORED ELECTRIC CHICAGO MODEL 116.101.AB.1 0.050GPM"

End of Addendum (7)