



September 20, 2022

AU Properties, LLC
Joseph's Place
Blossburg Behavioral Health Center Renovations Project
AJH Project 21-092

ADDENDUM NO. 4

The following Addendum shall be considered a part of the contract documents prepared by AJH Design dated July 5, 2022.

Drawings Issued by This Addendum:

A-7.1 - Door Schedule
E-2.2 – Building A, B First Floor Lighting Plan (Base Bid)

Revisions to Project Manual

ITEM AD 4-1 Refer to Section 01 10 00 – Summary:

Add paragraphs 1.7, B, 15 and 16 to read as follows:

“15. All exterior windows, doors, and associated hardware shall be provided and installed as part of Base Bid work. Solid surface sills at Building-B second and third floors shall be omitted.”

“16. All work at concrete areaways at basement/ground floor windows shall be provided in Base Bid work.”

ITEM AD 4-2 Refer to Section 01 23 00 – Alternates:

Add paragraph 3.1, A, 6 and 7 Alternate 1, to read as follows:

“6. Provide solid surface windowsills as part of work included in Alternate No. 1. Base bid excludes solid surface sills within Alternate 1 area.

“7. Base bid shall include all exterior wall mounted light fixtures, video surveillance cameras, and CH-B1 chiller.

ITEM AD 4-3 Refer to Section 01 23 00 – Alternates:

Add paragraph 3.1, A, 7., Alternate 1, to read as follows: “6. Provide solid surface windowsills as part of work included in Alternate No. 1. Base bid excludes solid surface sills within Alternate 1 area.

ITEM AD 4-4 Refer to Section 01 23 00 – Alternates:

Amend paragraph 3.1, F, 2, Alternate 6, to read as follows: “Masonry restoration includes repointing brick, brick replacement, removal and replacement of specific brick areas, precast concrete exterior sills, and concrete accent band replacement. Refer to contract drawings for the extent of work and locations.”

ITEM AD 4-5 Refer to Section 01 23 00 – Alternates:

Add paragraph 3.1, G, 5, Alternate 7, to read as follows: “5. Provide solid surface windowsills as part of work included in Alternate No. 7. Base bid excludes solid surface sills within Alternate 7 area.”

ITEM AD 4-6 Refer to Section 01 23 00 – Alternates:

Add paragraph 3.1, H, 6, Alternate 8, to read as follows: “6. Provide solid surface windowsills as part of work included in Alternate No. 8. Base bid excludes solid surface sills within Alternate 8 area.”

ITEM AD 4-7 Refer to Section 08 71 00 – Door Hardware:

Amend paragraph 2.6, A, 2, to read as follows:

2. Lock Manufacturers: Subject to compliance with requirements, provide lockset products of the following approved manufacturers:
 - a. Falcon (T-Series).
 - b. Sargent Lock Co. "10 Line".
 - c. Corbin Russwin CLX3300 Series.
 - d. Best Lock Co. "93K Series".
 - e. Schlage Lock Co. "ND Series".

ITEM AD 4-8 Refer to Section 08 71 00 – Door Hardware:

Amend sentence 2.7, F to read as follows:

- F. Acceptable Manufacturers and Products:
 1. Falcon Closers "SC70 Series"
 2. Norton "7500 Series"
 3. Sargent "350 Series"
 4. Yale "4400 Series"
 5. LCN Closers "1460 Series"

ITEM AD 4-9 Refer to Section 08 71 00 – Door Hardware:

Add the following hardware groups to paragraph 3.4 – Schedule:

Qty Act	Qty Inact	Description		Finish	Mfr
Heading 3A					
3	0	4-1/2 Std Wt (.134) Hinge	TA2714 4-1/2" x 4-1/2"	26D	McKinney
1	0	Storeroom Cylindrical Lever	28-10G04 x LL	US26D	Sargent
1	0	Closer	351-UO	EN	Sargent
1	0	Kickplate	Kick Plate X .050 X 10"h {2" LWOD}	US32D	Burns Mfg
1	0	Surface Overhead Stop	1548S	US26D	Sargent
3	0	Silencer	SR64	GRY	Ives
Heading 3B					
3	0	4-1/2 Std Wt (.134) Hinge	TA2714 4-1/2" x 4-1/2"	26D	McKinney
1	0	Storeroom Cylindrical Lever	28-10G04 x LL	US26D	Sargent
1	0	Kickplate	Kick Plate X .050 X 10"h {2" LWOD}	US32D	Burns Mfg
1	0	Surface Overhead Stop	1548S	US26D	Sargent
3	0	Silencer	SR64	GRY	Ives

Heading 4C

3	0	4-1/2 Std Wt (.134) Hinge	TA2714 4-1/2" x 4-1/2"	26D	McKinney
1	0	Entry/Office Cylindrical Lever	28-10G05 x LL	US26D	Sargent
1	0	Closer	351-UO	EN	Sargent
1	0	Wall Stop	3210T	US26D	DCI
3	0	Silencer	SR64	GRY	Ives

Heading 6A

3	0	4-1/2 Std Wt (.134) Hinge	TA2714 4-1/2" x 4-1/2"	26D	McKinney
1	0	Passage Set	28-10U15 x LL	US26D	Sargent
1	0	Closer	351-UO	EN	Sargent
1	0	Kickplate	Kick Plate X .050 X 10"h {2" LWOD}	US32D	Burns Mfg
1	0	Surface Overhead Stop	1548S	US26D	Sargent
3	0	Silencer	SR64	GRY	Ives

ITEM AD 4-10 Refer to Section 22 10 05 – Plumbing Piping:

Amend paragraph 1.5 Quality Assurance to read as follows:

- A. Perform Work in accordance with the state of Pennsylvania, Standards.

ITEM AD 4-11 Refer to Section 22 10 05 – Plumbing Piping:

Amend paragraph 1.6 Regulatory Requirements to read as follows:

- A. Perform Work in accordance with the state of Pennsylvania, Plumbing Code.

ITEM AD 4-12 Refer to Section 22 10 05 – Plumbing Piping:

Amend paragraph 3.6 Disinfection of Domestic water piping system to read as follows:

- B. Final water samples shall be sent to a Pennsylvania State Department of Health-approved testing lab and sample test results shall be submitted to A/E of record.

ITEM AD 4-13 Refer to Section 22 10 05 – Plumbing Piping:

Amend paragraph 3.7 Service Connections to read as follows:

- A. Test sanitary waste and vent piping system in accordance with the State of Pennsylvania Plumbing Code and local jurisdiction.
- B. Test domestic CPVC water piping system in accordance with the State of Pennsylvania Plumbing Code and local jurisdiction.
- C. Test gas piping system in accordance with Fuel Gas Code of the State of Pennsylvania.

ITEM AD 4-14 Refer to Section 23 09 23 – Direct Digital Control System:

Amend Title 1.3 which reads "Approved Control System Contractors and Manufacturers...." to read as follows: "Control System Contractors and Manufacturers".

ITEM AD 4-15 Refer to Section 23 09 23 – Direct Digital Control System:

Amend paragraph 1.3 (b) to read as follows: "Additional Manufacturers meeting specified performance requirements may be provided with universal BACnet capabilities. Acceptance of alternate manufacturers shall be the sole responsibility of the Architect/Engineer."

Revisions to Drawings

ITEM AD 4-16 Refer to Drawing G-3.1 – Base Bid and Alternates:

Amend Detail 2/G-3.1 Alternate 1 boundary to exclude the Chiller located exterior of the building on the south end of the building.

ITEM AD 4-17 Refer to Drawing A-1.1 – Building A Ground Floor & Building B Basement Plans (Base Bid):

Amend Door B010B- 2 to be a Single Swing Door, left-hand swing.

ITEM AD 4-18 Refer to Drawing A-7.1 – Door Schedule:

Delete Drawings A-7.1 – Door Schedule and replace it with Drawing A-7.1 issued by this addendum.

ITEM AD 4-19 Refer to Drawing A-7.2 – Door& Window Schedules and Details:

Add note in the Remarks column of the Storefront Glazing Schedule that reads: "Refer to Section 08 41 23 Fire Rated Aluminum Frames" at storefront glazing openings B121-3, B121-4, and B121-5.

ITEM AD 4-20 Refer to Drawing M-4.1 – Bldg. B Enlarged Mechanical Room Floor Plan and Elevations:

Add the following note in Detail 1/M-4.1 – Building-B Mechanical Room, at both glycol feed system units GMU-B1 and GMU-B2: "Provide J.L. Wingert co. GL50-E Glycol Feed System. Provide glycol for heating and cooling system. The percentage shall be 30% for both systems. Provide a total of 20 gallons of additional glycol for B-Building Boiler Room B017 in 5-gallon containers."

ITEM AD 4-21 Refer to Drawing M-4.2 – Bldg. A Enlarged Mechanical Room Floor Plan and Elevations:

Add the following note in Detail 1/M-4.2 – Building-A Mechanical/Electrical Room A006, at both glycol feed system units GMU-A1 and GMU-A2: "Provide J.L. Wingert co. GL50-E Glycol Feed System. Provide glycol for heating and cooling system. The percentage shall be 30% for both systems. Provide a total of 20 gallons of additional glycol for A-Building Boiler Room A006 in 5-gallon containers."

ITEM AD 4-22 Refer to Drawing P-3.1 – Plumbing Sections & Details:

Amend the title "GWH Piping System" of detail No.-11/P-3.1 to read "Heat exchanger Piping System".

ITEM AD 4-23 Refer to Drawing P-1.1 – Bldg. A Ground Floor & Bldg. B Basement Domestic Piping Plans:

Add the following note at Mechanical Room A-006 in Detail 1/P-1.1 Bldg. A-Ground Floor Domestic Piping Plan (Base Bid) and Mechanical Room B017 in Detail 2/P-1.1 Bldg. B-Basement Floor domestic Piping Plan (Base Bid): "Provide and Install water softener. Water softener shall be installed on the incoming main water service, after the backflow prevention device, and before any branch lines".

ITEM AD 4-24 Refer to Drawing P-3.1 – Plumbing Sections & Details:

Delete the text "GWH-1 & GWH-2" in detail 11/P-3.1.

ITEM AD 4-25 Refer to Drawing P-4.2 – Enlarged Domestic Water Supply Plans:

Amend Detail 1/P-4.2 Bldg. B-Mechanical Room DWS Plan, text that reads "Fire Sprinkler connection, by sprinkler Designer": To read "Fire Sprinkler connection, by Contractor".

ITEM AD 4-26 Refer to Drawing P-5.1 – Plumbing schedules:

Amend CP-1, RCP_1 and SK-4 fixtures to read as follows in the Plumbing Fixture Schedule:

Name	Description	Manufacturer	Model No.	Remarks
CP-1	Circulation Pump	Bell and Gossett	Ecocirc+ 20-18	
RCP-1	Re-Circulation Pump	Bell and Gossett	Ecocirc+ 20-18	
SK-1	Stainless Steel Single Bowl Sink	American Standard	Colony 22SB.6252283 C.075	25"X22"X6" with Colony PRO Single Control Faucet and strainer plate.
SK-4	Stainless steel single bay utility sink	Steelton	522CS12424	24"X24"X12" bowl with 5PR-8W12 faucet and removable strainer.

ITEM AD 4-27 Refer to Drawing E-1.2 – Bldg. A & Bldg. B First Floor Power Plan (Base Bid):

Delete all Keynotes 1 & 2 shown in Mechanical Room B017 in Detail 1/E-1.2 - Building B First Floor Power Plan – (Base Bid).

ITEM AD 4-28 Refer to Drawing E-2.2 – Bldg. A, B First Floor Lighting Plan (Base Bid):

Delete Drawings E-2.2 – Bldg. A, B First Floor Lighting Plan (Base Bid) and replace it with Drawing E-2.2 issued by this addendum.

End of Addendum

DOOR SCHEDULE

TAG	DOOR				FRAME						FIRE RATING	HARDWARE	REMARKS				
	PAIR	SIZE		TYPE	MATERIAL	FINISH	GLASS	DETAIL									
		WIDTH	HEIGHT					HEAD	JAMB	SILL							
A001-1	4'-0"	6'-8"	1'3/4"	6	WD	STAIN	SG	A	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	5A	BASE BID	
A002-1	3'-0"	7'-0"	1'3/4"	6	WD	STAIN	SG	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5A	ALTERNATE 8	
A003-1	3'-0"	7'-0"	1'3/4"	6	WD	STAIN	SG	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5A	ALTERNATE 8	
A004-1	3'-0"	7'-0"	1'3/4"	6	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5A	ALTERNATE 8	
A005-1	3'-0"	6'-8"	1'3/4"	6	WD	STAIN	SG	A	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	5A	ALTERNATE 8	
A006-1	4'-0"	6'-8"	1'3/4"	3	HM	PAINT	---	A	HM	PAINT	13A-7.3	3A-7.3	23A-7.3	---	5A	ALTERNATE 8	
A007-1	(2) 2'-6"	5'-0"	6'-8"	1'3/4"	5	HM	PAINT	FRG	A	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	45 MIN	9	BASE BID
A007-2	3'-0"	6'-11"	2"	1	ALUM	KYNAR	IG-A	C	ALUM	KYNAR	10A-7.3	1A-7.3	21,24A-7.3	---	1	BASE BID	
A008-1	3'-0"	6'-8"	1'3/4"	6	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	45 MIN	3	BASE BID	
A009-1	3'-0"	6'-11"	2"	1	ALUM	KYNAR	IG-A	F	ALUM	KYNAR	10A-7.3	1A-7.3	21,24A-7.3	---	1	BASE BID	
A009-2	3'-0"	6'-8"	1'3/4"	6	WD	STAIN	SG	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	8	ALTERNATE 8	
A010-1	3'-0"	6'-8"	1'3/4"	3	HM	PAINT	---	A	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	45 MIN	3	ALTERNATE 8	
A010-2	4'-0"	6'-8"	---	---	---	---	---	---	---	---	---	---	---	---	---	(CASED OPENING) ALT. 8	
A011-1	3'-0"	7'-0"	1'3/4"	6	WD	STAIN	SG	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	7	ALTERNATE 8	
A011-2	3'-0"	6'-8"	1'3/4"	6	WD	STAIN	---	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	7	ALTERNATE 8	
A012-1	4'-0"	6'-8"	1'3/4"	4	HM	PAINT	FRG	B	HM	PAINT	13A-7.3	3A-7.3	23A-7.3	45 MIN	4C	ALTERNATE 8	
A012-2	2'-8"	7'-0"	1'3/4"	3	HM	PAINT	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	15	ALTERNATE 8	
A013-1	3'-0"	6'-11"	2"	1	ALUM	KYNAR	IG-A	B	ALUM	KYNAR	10A-7.3	2A-7.3	23A-7.3	---	1	BASE BID	
A013-2	3'-0"	6'-11"	2"	1	ALUM	KYNAR	IG-A	B	ALUM	KYNAR	10A-7.3	2A-7.3	23A-7.3	---	1	BASE BID	
A014-1	3'-0"	6'-8"	1'3/4"	4	HM	PAINT	FRG	A	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	45 MIN	4	ALTERNATE 8	
A014-2	4'-0"	7'-0"	1'3/4"	4	HM	PAINT	SG	A	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	20	ALTERNATE 8	
A015-1	3'-0"	6'-8"	---	---	---	---	---	---	---	---	---	---	---	---	---	ALTERNATE 8	
A016-1	3'-0"	6'-8"	1'3/4"	3	HM	PAINT	---	A	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	6	ALTERNATE 8	
A017-1	3'-0"	6'-8"	1'3/4"	6	WD	STAIN	SG	A	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	7	ALTERNATE 8	
A018-1	3'-0"	6'-8"	1'3/4"	6	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	3	ALTERNATE 8	
A019-1	3'-0"	6'-8"	1'3/4"	6	WD	STAIN	SG	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	15	ALTERNATE 8	
A020-1	3'-0"	6'-8"	1'3/4"	3	HM	PAINT	---	A	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	6	ALTERNATE 8	
A021-1	(2) 2'-6"	5'-0"	6'-8"	1'3/4"	5	HM	PAINT	FRG	A	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	45 MIN	9	BASE BID
A021-2	3'-0"	6'-11"	2"	1	ALUM	KYNAR	IG-A	C	ALUM	KYNAR	10A-7.3	1A-7.3	21,24A-7.3	---	1	BASE BID	
A022-1	3'-0"	6'-8"	1'3/4"	3	HM	PAINT	---	A	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	20 MIN	12A	ALTERNATE 8	
A101-1	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	90 MIN	12	BASE BID	
A102-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	8	BASE BID	
A102A-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5	BASE BID	
A103-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	5	BASE BID	
A103A-1	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5	BASE BID	
A104-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	13A-7.3	3A-7.3	23A-7.3	---	8	BASE BID	
A104A-1	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5	BASE BID	
A105-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	13A-7.3	3A-7.3	23A-7.3	---	8	BASE BID	
A105A-1	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5	BASE BID	
A107-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	13A-7.3	3A-7.3	23A-7.3	---	3	BASE BID	
A108-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	8	BASE BID	
A108A-1	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5	BASE BID	
A109-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	3	BASE BID	
A110-1	(2) 2'-6"	5'-0"	6'-8"	1'3/4"	6	WD	STAIN	FRG	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	45 MIN	9	BASE BID
A111-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	13A-7.3	3A-7.3	23A-7.3	---	5A	BASE BID	
A112-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	8	BASE BID	
A112A-1	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5	BASE BID	
A113-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	13A-7.3	3A-7.3	23A-7.3	---	8	BASE BID	
A113A-1	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5	BASE BID	
A114-1	(2) 2'-6"	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	90 MIN	11	BASE BID
A115-1	(2) 3'-0"	6'-0"	6'-8"	1'3/4"	6	WD	STAIN	SG	B	HM	PAINT	13A-7.3	3A-7.3	23A-7.3	---	14	BASE BID
A115-2	3'-0"	7'-0"	2"	1	ALUM	KYNAR	IG-A	B	ALUM	KYNAR	10A-7.3	2A-7.3	23A-7.3	---	21	BASE BID	
A116-1	(2) 3'-0"	6'-0"	6'-8"	2"	1	ALUM	KYNAR	IG-A	B	ALUM	KYNAR	17A-7.3	9A-7.3	22A-7.3	---	9	BASE BID
A116-2	(2) 3'-0"	6'-0"	6'-8"	2"	1	ALUM	KYNAR	IG-A	B	ALUM	KYNAR	10A-7.3	2A-7.3	19A-7.3	---	2	BASE BID
A118-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	8A	BASE BID	
A119-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	13A-7.3	3A-7.3	23A-7.3	45 MIN	3	BASE BID	
A120-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	8A	ALTERNATE 7	
A121-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	13A-7.3	3A-7.3	23A-7.3	---	5	BASE BID	
A121A-1	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5	BASE BID	
A122-1	(2) 2'-6"	5'-0"	6'-8"	1'3/4"	6	WD	STAIN	FRG	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	45 MIN	9	BASE BID
A201-1	(2) 2'-6"	5'-0"	6'-8"	1'3/4"	6	HM	PAINT	FRG	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	45 MIN	9	BASE BID
A202-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	8	ALTERNATE 7	
A202A-1	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5	ALTERNATE 7	
A203-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	13A-7.3	3A-7.3	23A-7.3	---	5A	ALTERNATE 7	
A204-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5	ALTERNATE 7	
A204A-1	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	8	ALTERNATE 7	
A205-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	13A-7.3	3A-7.3	23A-7.3	---	8	ALTERNATE 7	
A205A-1	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5	ALTERNATE 7	
A206-1	2'-8"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	3	ALTERNATE 7	
A209-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	45 MIN	3	ALTERNATE 7	
A210-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	8	ALTERNATE 7	
A210A-1	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5	ALTERNATE 7	
A211-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	45 MIN	3	ALTERNATE 7	
A212-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	9	ALTERNATE 7	
A212A-1	3'-0"	7'-0"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	15A-7.3	5A-7.3	23A-7.3	---	5	ALTERNATE 7	
A213-1	3'-0"	6'-8"	1'3/4"	2	WD	STAIN	---	B	HM	PAINT	12A-7.3	3A-7.3	23A-7.3	---	8	ALTERNATE 7	
A213A-1	3'-0"	7'-0"	1'3/4"	2</													

