



Addendum

Onondaga-Cortland-Madison BOCES
Syracuse, New York

SED No. 42-90-00-00-001-025

Reconstruction at
McEvoy Educational Center

Tt Project No. 07901-20002

BID Addendum No. 3
to
Drawings and Project Manual

December 29, 2020

To: BIDDERS

This ADDENDUM forms a part of the BIDDING AND CONTRACT DOCUMENTS and modifies the following documents:
Original DRAWINGS dated June 19, 2020.
PROJECT MANUAL dated June 19, 2020, BID ADDENDUM NO. 1, dated December 18, 2020 and BID ADDENDUM NO. 2, dated December 28, 2020.

Acknowledge receipt of the ADDENDUM in the space provided on the BID FORM.

This ADDENDUM consists of (1) page and the following:

ATTACHMENTS

PRE-BID REQUEST FOR INTERPRETATIONS QUESTIONS/ANSWERS

PROJECT MANUAL MODIFICATIONS

ITEM 3-C-1: Refer to SECTION 00 11 13 - NOTICE TO BIDDERS

1. ADD the following after the Fourth Paragraph that begins with "A pre-bid conference..."

"Due to the snowstorm that occurred on December 17th, a make-up walk through to see the facilities will be held on Thursday, December 31, 2020, at 10:00 AM. Meet in the Dining Courtyard."

ITEM 3-C-2: Refer to SECTION 00 21 13 – INSTRUCTIONS TO BIDDERS

1. Article 1, Item 5., ADD the following:

"d. Due to the snowstorm that occurred on December 17th, a make-up walk through to see the facilities will be held on Thursday, December 31, 2020, at 10:00 AM. Meet in the Dining Courtyard."

END OF ADDENDUM



INSTRUCTIONS TO BIDDERS
ATTACHMENT #1:
PRE-BID REQUEST FOR INTERPRETATION FORM

SUBMIT FORM BY EMAIL TO TAE.OCMBOCES@tetrattech.com

Project No.: 07901-20002

Date: 12/28/2020

Project Name: OCM BOCES McEvoy Auditorium AC

Bidder Contact Person: Steve Porter
Bidder Company Name: Emerald Electrical Contractors, Inc.
Bidder Phone: 315-475-9607
Bidder Email Address: sporter@emerald-electric.com

Question Pertains to:

Drawing Number: E100
Plan Area:
Room Number:
Drawing Detail Number: KEYED NOTE #7 (per addenda #2)
Specification Section:

Question: (Please be specific) Addenda #2 asks for (3) relays to control each of the existing ceiling fans (3). Can it be verified that these ceiling fans are in fact on their own circuit? Thank you

Review by Architect/Engineers: _____ **Responded By:** Dennis J. Smith **Date:** 12/28/2020

The fans are existing and it has not been confirmed that they are on one circuit.

Submit requests not less than 5 working days prior to the specified Bid Opening date and time. In the event that this question requires clarification or modification of the Bidding Documents, such written information can only be provided by formal Addendum, distributed to all plan holders.



INSTRUCTIONS TO BIDDERS
ATTACHMENT #1:
PRE-BID REQUEST FOR INTERPRETATION FORM

SUBMIT FORM BY EMAIL TO TAE.OCMBOCES@tetrattech.com

Project No.: 07901-20002

Date: 12/28/2020

Project Name: OCM BOCES McEvoy Auditorium AC

Bidder Contact Person: Steve Porter
Bidder Company Name: Emerald Electrical Contractors, Inc.
Bidder Phone: 315-475-9607
Bidder Email Address: sporter@emerald-electric.com

Question Pertains to:

Drawing Number: E100
Plan Area:
Room Number:
Drawing Detail Number: KEYED NOTE #1 and #2
Specification Section:

Question: (Please be specific) As both panel boards are recessed and the ceilings are gypsum, is it the architect's intention for the EC to provide and install access panels as needed down the corridors for the feeder conduits to the RTUs? Or would this be in the GC contract? Thank you.

Review by Architect/Engineers:

Responded By: Dennis J. Smith **Date:** 12/28/2020

Refer to drawing A100 for extent of ceiling work.

Submit requests not less than 5 working days prior to the specified Bid Opening date and time. In the event that this question requires clarification or modification of the Bidding Documents, such written information can only be provided by formal Addendum, distributed to all plan holders.

