



**DESIGN & CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242**

---

**ADDENDUM NO. 2 TO PROJECT NO. 47621**

**CONSTRUCTION, PLUMBING AND ELECTRICAL WORK  
UPGRADE ELECTRICAL SERVICE  
STATE ARMORY  
85 WEST END AVE.  
BINGHAMTON, NY**

August 26, 2024

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**ELECTRICAL WORK SPECIFICATIONS**

1. Page 263213-7, Paragraph 2.01.H.8, Change Paragraph 8 to read:
  - “8. Main circuit breaker mounted on unit, or on mounting frame adjacent to unit. Circuit breaker shall be listed and labeled as defined in NFPA 70, by an NRTL, and marked for intended location and application. Field circuit breaker not acceptable as the main circuit breaker.”

**END OF ADDENDUM**

Brady Sherlock, P.E.  
Director, Division of Design  
Design & Construction