



**DESIGN & CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242**

ADDENDUM NO. 2 TO PROJECT NO. 45260

**CONSTRUCTION, HVAC, PLUMBING AND ELECTRICAL WORK
PROVIDE RESTROOM AND LOCKER ROOM ADDITION
DOT REGION 6, SCHUYLER COUNTY
3545 COUNTY ROUTE 16
WATKINS GLEN, NY**

June 30, 2022

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

CONSTRUCTION WORK DRAWINGS

1. Drawing No. C-201:
 - a. Key Notes: Change Key note #13 to Read:
"Existing fencing to remain"
 - b. Key Notes: Change Key note #14 to Read:
"Existing manual slide gate to remain"
2. Drawing No. C-301:
 - a. Key Notes: Change Key note #20 to Read:
"Existing fencing to remain"
 - b. Key Notes: Change Key note #21 to Read:
"Existing manual slide gate to remain"
3. Drawing No. S-502:
 - a. Detail #1: Change note which states "(2) #5's @ 48" and at top and bottom of wall (cont)" to Read:
"Provide bond beam with (2) #5's at the top and bottom of wall (cont). Provide bond beams with (2) #5's at 48" intervals starting above slab (cont)."

END OF ADDENDUM

Erik T. Deyoe, P.E.
Director, Division of Design
Design and Construction