

## **BID ADDENDUM NO. 5**

Date: January 11, 2022

Prattsburgh CSD

Project: Capital Improvements Project – Phase 2

HUNT No.: 2716.025

Prattsburgh CSD School SED Main Building #: 57-23-01-04-0-001-026

Prattsburgh CSD School SED Main Building #: 57-23-01-04-0-001-027

Prattsburgh CSD School SED Auxillary Building #: 57-23-01-04-0-002-011

The following Addendum items shall be considered a part of the contract documents prepared by HUNT ENGINEERS, ARCHITECTS, LAND SURVEYORS & LANDSCAPE ARCHITECT, DPC.,  
Project Date: August 13, 2021, Issued for Bid Date December 7, 2021

**Clarifications:**

None

**Project Manual Sections issued by this Addendum:**

None

**Drawings issued by this Addendum:**

None

**Revisions to Project Manual issued by this Addendum:**

**ITEM AD5-1 Refer to Section 00 11 13 – Advertisement for Bids**

AMEND paragraph 3 to read: “Sealed bids will be received by the Owner until 2:00 P.M. local time on **January 19, 2022** at Prattsburgh Central School District office, 1 Academy St. Prattsburgh, NY 14873, at which time and place all bids will be opened and publicly read aloud.”

**ITEM AD5-2 Refer to Section – 10 21 13.17 – Phenolic Toilet Compartments**

ADD subparagraph 2.2, D, 3, to read: “Provide perpendicular pilasters at individual shower compartments, and provide head rail bracing between pilasters at each shower compartment.”

**ITEM AD5-3 Refer to Section – 10 28 00 – Toilet, Bath and Laundry Accessories**

AMEND subparagraph 2.3, A, 1, b to read: “Dimensions 1-1/2 inch outside diameter, minimum 0.05 inch wall thickness, exposed flange mounting, 1-1/2 inch clearance between wall and inside of grab bar.”

**Revisions to Drawings issued by this Addendum:**

**ITEM AD5-4 Refer to Drawing A5.1 – Enlarged Toilet Plans and Details**

**AMEND** Toilet Room Accessory Schedule, item 4-mirror, model column to read: “#0535 Series- ASI”.

**AMEND** Toilet Room Accessory Schedule, item 4-mirror, size column to read: “24”w x 30”h”.

**AMEND** Toilet Room Accessory Schedule, item 4-mirror, remarks column to read: “Provide ASI 0535-2430 Fixed Tilt ADA Compliant Mirror at all locations indicated.”

**AMEND** Toilet Room Accessory Schedule, item 7-shower partitions, model column to read: “Phenolic per specification 10 21 13.17”.

**AMEND** Toilet Room Accessory Schedule, item 8-shower curtain rod, size column to read: “As indicated/dimensioned on drawings.”

**DELETE** “Concealed Mounting” from Toilet Room Accessory Schedule, item 8-shower curtain rods, remarks column.

**DELETE** “B-3944” and “16” x 54-3/4” x 4” min. depth” from Toilet Room Accessory Schedule, item 9-shower curtain, model and size columns.

**AMEND** Toilet Room Accessory Schedule, item 9-shower curtain, remarks column to read: “72” height, refer to dimensions indicated on drawings for width, refer to spec 10 28 00.”

End of Addendum (5)

ACKNOWLEDGMENT OF RECEIPT BY:

LEGAL NAME OF BIDDER: \_\_\_\_\_

BY (Signature & Title): \_\_\_\_\_

DATE: \_\_\_\_\_

THIS PAGE SHALL BE ATTACHED TO AND SUBMITTED WITH THE BID PROPOSAL.