

Questions & Answers - 3

Project JW-000000131-RFP_F - Recycling Center Phase 2
Buying Organization Tompkins County

No	Question/Answer	Question Date
Q5	<p>Question: Sprinkler Head</p> <p>Drawings state existing sprinkler head to remain. During walk-through, it was noticed there is no sprinkler head within the vestibule. Please advise what should happen. Are we to provide new? Add a dry system?</p> <p>Answer: Provide a new dry sprinkler system serving the vestibule, including a dry-type sprinkler head and all associated piping and appurtenances necessary to comply with NFPA 13 and the project requirements. Coordinate the installation with the existing building sprinkler system and all other trades.</p>	06/04/2026