



G. R. NOTO Electrical Construction, Inc.



Shady Lane Business Park
2 Skyline Drive
P.O. Box 247
Clarks Summit, PA 18411

Phone: (570) 586-1600
FAX: (570) 586-2700

REQUEST FOR INFORMATION

Job Name: Tri-County REC - Office & Warehouse Job # _____

To: Estimating Department Attention: _____

Requested By Ryan Call

Description _____

Dwg Ref _____

Spec Ref _____

Information Requested

Please clarify the following:

- | | | | |
|---------------|-------------------------------|-------------------------|---------------------------------------|
| * Video Wall | * Qty. of Ceiling Microphones | * Camera Video Recorder | * Door Security |
| * Panel Size | * Riser Shows (2) | * How Much Storage | * What is supplied with door hardware |
| * Bezel Width | * Dwg. 1T-1.1 shows (3) | | |
| * Brightness | | | |

Signature Ryan Call Date 4/15/21

Reply

All,
 The attached RFI was received, and the following is our formal response.

- Video Wall Basis of design is Planar LX55M, screen size is 55", bezel is .88 mm, brightness is 500 nits.
- Quantity of ceiling microphones is two (2).
- Contractor to calculate storage based on requirements found in Specification 281302 Security Video Surveillance System, Section 2.2, Part D.
- Regarding door security, from a function standpoint, we are using electrified storeroom locksets with credential reader and power supply. The schematic for this is shown on 1E-5.02.

Thanks,

Brian P. Sabla, CSI, CCS, LEED AP, BD+C
 Project Manager

Signature _____ Date _____