

RFI RESPONSES 4-16-21

All,

See below for a few more questions and answers.

1). Civil Plan Sheet 6 of 10 Grading & Erosion Control – please advise on size and type of perimeter silt fence/compost filter sock desired. Label CSF on plans.

The silt fence is Siltron 21 type fencing, per the detail on sheet 7 of 10.

2). Civil Plan Sheet 6 of 10 Grading and Erosion Control – please provide size, type of rip rap and thickness required for rock aprons at HW 9, HW 8 & HW5. I do not see this information listed on the plan sheet or in a chart on the detail pages.

Rip rap is to be size R-4 and should be 18" deep.

3). Civil Plan Sheet 4 of 10 – Utility Plan – Are profiles available for the storm sewer runs? The only profiles I see are for the Sanitary Sewer and a General Site profile.

Being a private development there was no requirement for storm sewer profiles. The appropriate storm structure and pipe information is shown on the utility sheet 4 of 10.

4). Civil Plan 6 of 10 Grading & Erosion Control – will NAG S75 Erosion Control Blanket be acceptable for slopes 3:1 and greater? Nothing is labeled on plans. If a more robust ECB is required, please advise.

The detail on sheet 7 of 10 shows the detail for the erosion control blanket and specifies the blanket as C125 or approved equal. If the NAG S75 is an approved equal for this use, it would be acceptable.

Thanks,

Brian P. Sabla, CSI, CCS, LEED AP, BD+C
Project Manager